

## Produkt Specifikation

### Transportdiesel – EN 590

Egenskab	Enhed	Testmetode	Specifikation	
			min.	max.
<b>Klarhed, 20° C.</b>		<b>Visuel</b>	<b>Ren &amp; klar</b>	
<b>El ledningsevne</b>	<b>pS/m</b>	<b>ASTM D 2624/ISO 6297</b>	<b>Note 1</b>	
<b>Aske</b>	<b>Mass %</b>	<b>ASTM D 482/ISO 6245</b>		<b>0,01</b>
<b>Cetan index (tændvillighed)</b>		<b>ASTM D 4737/EN 4264</b>	<b>46</b>	
<b>Cetan nr. (tændvillighed)</b>		<b>ASTM D 613/ISO 5165</b>	<b>51</b>	
<b>Farve</b>		<b>ASTM D 1500/ISO 2049</b>		<b>2,0</b>
<b>Kuldeegenskaber:</b>				
<b>Uklarhedspunkt</b>	<b>° C.</b>	<b>ASTM D 5772/EN 23015</b>		<b>0</b>
<b>16/3-30/9</b>				<b>÷7</b>
<b>1/10-30/11</b>				<b>÷10</b>
<b>1/12-15/3</b>				
<b>Cold Filter Plugging Point</b>	<b>° C.</b>	<b>EN 116/IP 309</b>		<b>÷12</b>
<b>16/3-30/9</b>				<b>÷18</b>
<b>1/10-30/11</b>				<b>÷24</b>
<b>1/12-15/3</b>				
<b>Vægtfylde, 15° C</b>	<b>Kg/m<sup>3</sup></b>	<b>ASTM D 4052/EN ISO 3675/EN ISO 12185</b>	<b>820,0</b>	<b>860,0</b>
		<b>ASTM D 86/EN 3405</b>		
<b>Destillation:</b>				
<b>65% genvundet ved</b>	<b>° C.</b>		<b>250</b>	
<b>85% genvundet ved</b>	<b>° C.</b>			<b>350</b>
<b>95% genvundet ved</b>	<b>° C.</b>			<b>360</b>
<b>Genvundet eller</b>	<b>Vol. %</b>		<b>98,0</b>	
<b>Destillationsrest</b>	<b>Vol. %</b>			<b>2</b>
<b>Flammepunkt, PM</b>	<b>° C.</b>	<b>ASTM D 93/ EN 2719</b>	<b>56</b>	
<b>Neutralisations Nummer:</b>				
<b>Syretal</b>	<b>mg KOH/g</b>	<b>ASTM D 664/D 974/ISO 6619</b>		<b>nul</b>
<b>Total syretal</b>	<b>mg KOH/g</b>	<b>ASTM D 664/D 974/ISO 6619</b>		<b>0,20</b>
<b>Svovl</b>	<b>mg/kg</b>	<b>ASTM D 5453/ EN ISO 20846/EN ISO20884</b>		<b>10</b>
	<b>(ppm)</b>			
<b>Smøreevne</b>	<b>my</b>	<b>ASTM D 6079/EN 12156</b>		<b>460</b>
<b>Viskositet, kin. ved 40° C.</b>	<b>mm<sup>2</sup>/s</b>	<b>ASTM D 445/ISO 3104</b>	<b>2,0</b>	<b>3,7</b>
<b>Vand Indhold</b>	<b>ppm</b>	<b>ASTM D 4928/EN ISO 12937</b>		<b>150</b>
<b>Biotilsætning</b>				
<b>FAME</b>	<b>% vol.</b>	<b>EN 14078</b>	<b>6,6</b>	<b>7,0</b>
<b>HVO</b>	<b>% vol.</b>		<b>6,6</b>	

1. Min. 10 pS/m ved læsning af tankbil.

10.12.13

PG